

**PROFORMA FOR SAFE DRINKING WATER AND  
SANITARY CONDITION CERTIFICATE**

No.

Dated: 06/01/25

It is certified that an inspection team headed by Dhaniseti Seenu  
(Name of Officers with designation) from Rural Water Supply and Sanitation Department  
(Name of Department/ Office) inspected the PRATHIBHA VIDYALAYAM HIGH SCHOOL  
SABBAVARAM, ANAKAPALLI  
(Name & Address of the school) on 06/01/25 (date of inspection), checked the water test report  
submitted by the school and found that the school has potable drinking water for students and staff of  
the institution and is having provision for running water in the toilets and maintaining hygienic  
sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/  
U.T. Govt.

The above is valid for a period of 6 months

Signature with Seal Asst. Executive Engineer

Name

RWS & S, Sabbavaram  
Dhaniseti Seenu

Designation :

Assistant Engineer  
09/01/25

Assistant Engineer of  
the Govt. Public Health Department  
(PHED)/Authorised officer of the Local  
Body

Name & Address of the Office / Department : .....

To

The Principal,

PRATHIBHA VIDYALAYAM HIGH SCHOOL,  
SABBAVARAM - 531035.

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



**Government of Andhra Pradesh**  
**Water Testing Laboratory,**  
**Rural Water Supply & Sanitation Department**  
**O/o Deputy Executive Engineer,**

**TEST REPORT ON CHEMICAL ANALYSIS OF WATER(DRINKING)**

**General physical Chemical Parameter**

**Name and address of Department officials : Prathibha Vidyalam High School Sabbavaram**

**Test Report ID No : 1**

**Description of the test items: Water Sample**

**Date of Collection : 06.01.2025**

**Date of issue : 08.01.2025**

Sl.No.	Physcio-Chemical Parameters	Units	As per IS (10500 - 2012)		Name of the location	Sample Result
			Requirement (Acceptable Limit)	Permissible Limit (in the absence of alternative source)		
1	Turbidity	NTU	0	5	SCHOOL	0
2	pH		6.5-8.5	No relaxation		7.21
3	Electrical Conductivity	micromhos/cm	-	-		140
4	Total Dissolved Solids	mg/lit	500	2000		98
5	Total Alkalinity as CaCO <sub>3</sub>	mg/lit	200	600		44
6	Total Hardness as CaCO <sub>3</sub>	mg/lit	200	600		36
7	Calcium as Ca <sup>++</sup>	mg/lit	75	200		6.4
8	Magnesium as Mg <sup>++</sup>	mg/lit	30	100		4.8
9	Flouride as F <sup>-</sup>	mg/lit	1.0	1.5		0.11
10	Chloride as Cl <sup>-</sup>	mg/lit	250	1000		15
11	Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/lit	45	No relaxation		2.1
12	Sulphate as SO <sub>4</sub> <sup>-</sup>	mg/lit	200	400		0
13	Iron as Fe	mg/lit	0.3	1.0		0

**REMARKS :Above sample is Chemically Satisfactory for drinking purpose.**

*R. Naidu*  
Lab Chemist  
W.Q.M.Lab,  
Sabbavaram

*[Signature]* 08/01/25  
Assistant Exe Engineer,  
RWS&S Sub Division,  
Sabbavaram





# Government of Andhra Pradesh

Water Testing Laboratory,  
Sabbavaram

Rural Water Supply & Sanitation Department

O/o Deputy Executive Engineer,  
RWS & S Sub-Division, Sabbavaram

## TEST REPORT ON BACTERIOLOGICAL ANALYSIS OF WATER(DRINKING)

S.N o	Date of collection	Name and address of Department officials	Name of the Location	H2S producing Bacteria	Total Coliform bacteria	E.Coil/100ml	Remarks
1	06.01.2025	Prathibha Vidyalayam High School Sabbavaram	School	No	<1	0	BACTERIOLOGICALLY SAFE

REMARKS : Above sample are Bacterillogically Safe for drinking purpose.

*G. Sun'basu*  
Micorbiologist,  
W.Q.M.Lab,  
Sabbavaram

*[Signature]*  
Assistant Exe Engineer,  
RWS&S Sub Division,  
Sabbavaram